WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39466
Permit No.
Basin 48

NOTICE OF INTENT NO. 21001

1. OWNER HILE CONSTRUCTION
MAILING ADDRESS P.O. Box 781
Elko, NV 89803

ADDRESS AT WELL LOCATION Southside of Pershing between 16th and 17th

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 32 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 28-024-03 (Parcel No.) Luckey Nugget #2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Sandy clay and gr.		2	25	23
Red sandstone		25	40	15
Brown sandstone		40	130	90
Brown siltstone & some gravel		130	330	200
Red clay		330	350	20
Brown siltstone	X	250	500	150

Date started August 2, 1992
Date completed August 5, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	35		3

STATE ENGINEERS OFFICE
AUG 27 AM 11:13
'92

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8	Inches	0 Feet	500 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	500

Perforations:
Type perforation Mill slot
Size perforation 2-1/2 x 1/4
From 460 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 350 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-25-1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627