

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18794

1. OWNER HILE CONSTRUCTION
 MAILING ADDRESS P.O. Box 781
Elko, NV 89801
 ADDRESS AT WELL LOCATION NW corner of
Sherman Avenue and 13th Street

2. LOCATION SE 1/4 SE 1/4 Sec. 17 T. 32 N/S R. 55 E. ELKO County
 PERMIT NO. 28-021-08 Luckey Nugget #2
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Grey clay		0	10	10
Red clay		10	18	8
Brown siltstone		18	42	24
Red clay		42	96	54
Brown siltstone		96	204	108
Red sandstone		204	216	12
Brown siltstone & gravel	X	216	420	204

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 420 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	420

Perforations:
 Type perforation Mill slot
 Size perforation 1/4 x 2-1/2

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 420 feet

9. WATER LEVEL
 Static water level 250 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started August 11, 1992
 Date completed August 12, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Blow test	<u>25</u>		

STATE ENGINEERS OF NEVADA RECEIVED
 92 AUG 27 AM 11:13

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number 020582
 issued by the State Contractor's Board

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller 1689

Signed Daniel Aden
 By driller performing actual drilling on site or contractor

Date 8-24-1992