WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39478
Permit No.
Basin 78

NOTICE OF INTENT NO. ~~17137~~ 20286

1. OWNER BOB MOORE R B DEVELOPMENT
MAILING ADDRESS 4700 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION ~~1950~~ MALLARD WAY
FALLON, NV 89406 71900

2. LOCATION NE ¼ NW ¼ Sec. 19 T. 30 N/~~S~~ R. 28 E. CHURCHILL County
PERMIT NO. NA (Issued by Water Resources) | 08-132-48 (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	9	9
CLAY		9	14	5
SILT		14	32	18
BLACK SAND		32	61	29
SAND & GRAVEL		61	70	9
CLAY		70	73	3
SAND & GRAVEL	X	73	88	15

'92 SEP -1 A11:11
STATE ENGINEER'S OFFICE

Date started AUGUST 25, 1992, 19
Date completed AUGUST 25, 1992, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN @ 20 GPM			

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 88 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	88	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	88

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 82 feet to 86 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 8'6" feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 60 °F Quality untstD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed (By driller performing actual drilling on site or contractor)
Date 8-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627