

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11136

1. OWNER Franklin & Sons, Inc. ADDRESS AT WELL LOCATION SE corner of  
MAILING ADDRESS 1580 S. Street Reno, Nev. 5th & Keystone

2. LOCATION S.F. Va. 66.6 Sec. 10 T. 19 R. 19 E. Unincorporated County  
PERMIT NO. m/c 499 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Test

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clayey sand w/ gravel</u> <u>bedrock</u>		<u>0</u>	<u>7.5</u>	<u>7.5'</u>
<u>Silty clayey sand</u> <u>bedrock</u>	<u>water</u>	<u>7.5</u>	<u>12.5</u>	<u>5'</u>
<u>Gravel w/ sand</u> <u>flow</u>		<u>12.5</u>	<u>17.5</u>	<u>5'</u>
<u>Sand</u> <u>flow</u>		<u>17.5</u>	<u>23.5</u>	<u>6'</u>
<u>Gravel w/ sand</u> <u>bedrock</u>		<u>23.5</u>	<u>44'</u>	<u>20.5'</u>

8. WELL CONSTRUCTION  
Depth Drilled 48 Feet Depth Cased 44 Feet

HOLE DIAMETER (BIT SIZE)  
From 5" Inches 0 Feet 44 Feet  
Inches.....Feet.....Feet  
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch. 40</u>	<u>0</u>	<u>44</u>

Perforations:  
Type perforation Factory slot  
Size perforation 0.250  
From 30 feet to 44 feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 10'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 10 feet to 44 feet

9. WATER LEVEL  
Static water level 3.7 feet below land surface  
Artesian flow no G.P.M. no P.S.I.  
Water temperature field °F Quality OK

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Franklin & Sons, Inc. Contractor  
Address 1635 Park Blvd Reno, Nev. Contractor  
Nevada contractor's license number issued by the State Contractor's Board 34525  
Nevada driller's license number issued by the Division of Water/Resources, the on-site driller 1028  
Signed Franklin & Sons, Inc. By driller performing actual drilling on site or contractor  
Date 03/31/92

Date started 10/19/92  
Date completed 10/19/92

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		