

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14178

1. OWNER Alvina Court # 0130 ADDRESS AT WELL LOCATION same
 MAILING ADDRESS Terminal way Reno NV
 2. LOCATION S.W. 1/4 NE 1/4 Sec 18 T 19 N/S R 20 E WASHIO County
 PERMIT NO. WFO 155 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG 14178

Material	Water Strata	From	To	Thick-ness
<u>Silty sand B.W</u>		<u>0</u>	<u>4</u>	<u>4'</u>
<u>sand w/silt</u>		<u>4'</u>	<u>6'</u>	<u>2'</u>
<u>sand B.W</u>		<u>6'</u>	<u>8'</u>	<u>2'</u>
<u>Coarse w/sand</u>		<u>8'</u>	<u>17'</u>	<u>5'</u>
<u>sand B.W</u>		<u>13'</u>	<u>15'</u>	<u>2'</u>
<u>Coarse w/sand</u>		<u>15'</u>	<u>18'</u>	<u>3'</u>
<u>sand</u>		<u>18'</u>	<u>20'</u>	<u>2'</u>
<u>Coarse w/sand</u>		<u>20'</u>	<u>30'</u>	<u>10'</u>

'92 SEP -3 AM 10:4
 STATE ENGINEER

Per A by log # 40127

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From 5 Inches 0 Feet 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch. 40</u>	<u>0</u>	<u>50</u>

Perforations:
 Type perforation factory slot
 Size perforation 2.0
 From 30 feet to 50 feet
 _____ feet to _____ feet
 _____ feet to _____ feet
 _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 7.5
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 7.5 feet to 30 feet

9. WATER LEVEL
 Static water level 19.5 feet below land surface
 Artesian flow 14/17 G.P.M. 14/17 P.S.I.
 Water temperature 62.2 °F Quality 14/17

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dan Anderson Contractor
 Address 1635 D. St. Reno NV
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Dan Anderson
 _____ by driller performing actual drilling on site or contractor
 Date 9/31/92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Date started 2/5 1992
 Date completed 2/5 1992