

OFFICE USE ONLY  
 Log No. 39493  
 Permit No. 89  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18664

1. OWNER John Roskey ADDRESS AT WELL LOCATION 7456 Old 395 N.  
 MAILING ADDRESS 7456 Old 395 N. Carson City, NV 89704  
Carson City, NV 89704  
 2. LOCATION SE 1/4 NW 1/4 Sec 23 T 16N N/S R 19 E Washoe County Washoe  
 PERMIT NO. 55-281-20 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown, Green, Grey streaks of top soil, d.g. with some clay		0	60	60
Grey and Green Clay		60	96	36
Green with some brown d.g. and gravel		96	145	49
White with brown small d.g. and gravel		145	160	15
White and brown gravels		160	220	60
Green clay with gravel		220	230	10

8. WELL CONSTRUCTION  
 Depth Drilled 230 Feet Depth Cased 230 Feet  
 HOLE DIAMETER (BIT SIZE)  
 10 1/4 Inches 0 From 160 To 160 Feet  
 6 1/2 Inches 160 From 160 To 230 Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160
5	10.79	.188	155	230

Perforations: Saw cut  
 Type perforation 3/32 x 3 single row  
 Size perforation 3/32 x 3 single row  
 From 145 feet to 160 feet  
 From 155 feet to 175 feet  
 From 200 feet to 220 feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 90  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 145 feet to 160 feet

9. WATER LEVEL  
 Static water level 29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality unknown

Date started 8-11, 1992  
 Date completed 8-13, 1992

7. WELL TEST DATA

Time (Hours)	Draw Down (Feet Below Static)	Time (Hours)
<u>21</u>	<u>85</u>	<u>2</u>
<u>27</u>		
<u>26</u>		

RECEIVED  
 DIVISION OF WATER RESOURCES  
 AUG 27 1992  
 9:00 AM

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Corp. Contractor  
 Address P.O. Box 888 Contractor  
Fallon, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-24-92