WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 739493
Permit No.
Basin 89

NOTICE OF INTENT NO. 18665

1. OWNER John Roskey
MAILING ADDRESS 7456 Old 395 N.
Carson City, NV 89704

ADDRESS AT WELL LOCATION 7456 Old 395 N.
Carson City, NV 89704

2. LOCATION SE ¼ NW ¼ Sec. 23 T. 16N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 55-281-20 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon well after perforating from 140' to approximately 50' at 5' intervals and at 90° apart at 4 perfs per interval. After perforating, 2½ yards of neat cement were pumped to bottom filling entire casing, the top of the well was cut off and backfilled. This was a 6 5/8" well 140' deep with water at 14'. The purpose for the abandonment was a new well was drilled to try and get water without strong odor and foul taste.				
Well drilled under Log 29180				

Date started 8-19, 19 92
Date completed 8-19, 19 92

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 8-25-'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627