WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39495
Permit No.
Basin

NOTICE OF INTENT NO. 16700

1. OWNER J C Penney
MAILING ADDRESS 11111 Stead Blvd Stead NV 89506
ADDRESS AT WELL LOCATION JC Penney 11111 Stead Blvd Stead NV 89506

2. LOCATION NE ¼ SW ¼ Sec. 31 T. 21 N/S R. 19 E. Washoe County
PERMIT NO. MB 273 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG North Well

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clayey Sand | Yes | 0 | 8 | 8 |
| Sandy Clay | Yes | 8 | 10.8 | 2.8 |

'92 SEP -3 A11:03
STATE ENGINEER'S OFFICE

Date started 5/27, 1992
Date completed 5/27, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 10.8 Feet Depth Cased 10.8 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 8 | 0 | 10.8 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | Sch. | 40 | 0 | 10.8 |
| | | | | |

Perforations:
Type perforation Factory Slot
Size perforation .020 Inches
From 0 feet to 10.8 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4.6 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4.6 feet to 10.8 feet

9. WATER LEVEL
Static water level 5.0 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Balfour RD. RENO NEV Contractor

Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/31/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627