WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39497
Permit No.
Basin 101

NOTICE OF INTENT NO. 16595

1. OWNER RUSSEL MILLER
MAILING ADDRESS 3750 LONDON CIRCLE FALLON, NV 89406
ADDRESS AT WELL LOCATION 3750 LONDON CIRCLE FALLON, NV 89406

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 18 N/S R. 28 E. CHURCHILL County
PERMIT NO. (Issued by Water Resources) 06-472-26 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN TOP SOIL		0	15	15
BROWN SAND		15	27	13
BLACK SAND		27	67	40
BLACK CLAY		67	69	2
GRAY CLAY		69	71	2
BROWN SAND		71	76	5

'92 SEP 11 A10:46
STATE ENGINEER'S OFFICE

Date started AUGUST 30, 19 92
Date completed AUGUST 31, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN	@ 30 GPM		

8. WELL CONSTRUCTION
Depth Drilled 76 Feet Depth Cased 76 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	76	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	76

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 71 feet to 74 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 15' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [signature]
By driller performing actual drilling on site or contractor

Date AUGUST 31, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627