WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39498
Permit No.
Basin 101

NOTICE OF INTENT NO. 16590

1. OWNER JIM HARMON
MAILING ADDRESS 3280 LONETREE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5275 TOYUN DR
FALLON, NV 89406

2. LOCATION SE ¼ NE ¼ Sec. 22 T. ~~18~~ 19 N/~~S~~ R. 29 E. CHURCHILL County

PERMIT NO. N/A (Issued by Water Resources) | 6-433-66 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	08	08
GROWN CLAY		08	14	06
BROWN SILT		14	36	14
BLACK SILT		36	68	32
GREY CLAY		68	81	13
YELLOW SAND & GRAVEL		81	92	11
GREY CLAY		92	118	26
SAND & GRAVEL		118	130	12

'92 SEP -1 A11:11
STATE ENGINEER'S OFFICE

Date started AUG 27, 1992, 19
Date completed AUG 27, 1992, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN @ 50 GPM		

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 5/8 Inches		50 Feet	130 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	130

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 124 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 8'7" feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 61 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627