WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39502
Permit No.
Basin 101

NOTICE OF INTENT NO. 16583

1. OWNER FERGUSON CONSTRUCTION
MAILING ADDRESS 310 W. WILLIAMS AVENUE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5045 SANDALWOOD DRIVE
FALLON, NV 89406

2. LOCATION NW ¼ SE ¼ Sec. 29 T. 19 N/S R. 28 E CHURCHILL County

PERMIT NO. NA (Issued by Water Resources) | 08-651-75 (Parcel No.) | ELLIS LEWIS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0 | 19 | 19 |
| BROWN CLAY | | 19 | 23 | 4 |
| COARSE SAND | | 23 | 36 | 13 |
| BLACK SAND | | 36 | 48 | 12 |
| GREY SAND | | 48 | 60 | 12 |
| BROWN CLAY | | 60 | 69 | 9 |
| SAND & GRAVEL | | 69 | 88 | 19 |

'92 SEP -1 A11:11
STATE ENGINEER'S OFFICE

Date started AUGUST 26, 1992, 19
Date completed AUGUST 26, 1992, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| AIRBLOWN @ 50 G P M | | |

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 88 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | 0 Feet | 50 Feet | |
| 6 5/8 Inches | 50 Feet | 88 Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | 0 | 88 |

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 82 feet to 86 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 8'7" feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 60 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed (By driller performing actual drilling on site or contractor)
Date 8-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627