WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39504
Permit No.
Basin 101

NOTICE OF INTENT NO. 21318

1. OWNER La Mar Lee
MAILING ADDRESS P.O. Box 43
Fallon, Nev. 89407-0043

ADDRESS AT WELL LOCATION 995 E. Richards
Fallon, Nev. 89406

2. LOCATION N/E ¼ N/E ¼ Sec. 31 T. 19 N/S R. 29 E. Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 7-651-10 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	21	15
Fine Brown Sand		21	34	13
Fine Gray Sand		34	38	4
Green & Black Coarse				
Sand		38	41	3
Gray Fine Sand		41	50	9
Black & Green Fine				
Sand		50	64	14
Black & Green Coarse				
Sand		64	70	6
Gray Fine Sand		70	73	3
Black & Green Coarse				
Sand		73	81	8
Brown Coarse Sand		81	110	29
Brown Fine Sand	X	110	115	5

'92 SEP -2 A10:30 STATE ENGINEER

Date started August 20, 19 92
Date completed August 20, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	115 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	115

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 111 feet to 114 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 feet to 115 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 45 (Contractor)
FALLON, NEV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date August 21, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627