WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39505
Permit No.
Basin 101

NOTICE OF INTENT NO. 16584

1. OWNER JAMES MYERS
MAILING ADDRESS 75 S. CROOK ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 75 S. CROOK ROAD
FALLON, NV 89406

2. LOCATION NW ¼ NE ¼ Sec. 33 T. 19 N/S R. 29 E. CHURCHILL County
PERMIT NO. NA (Issued by Water Resources) 07-871-07 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	36	36
BROWN CLAY		36	38	2
BLACK SAND		38	92	54
BLACK CLAY		92	94	2
BROWN CLAY		94	96	2
BROWN SAND & GRAVEL	X	96	113	17

'92 SEP -1 A11:10
STATE ENGINEER'S OFFICE

Date started 08-27-92, 19
Date completed 08-28-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN @ 30 GPM		

8. WELL CONSTRUCTION
Depth Drilled 113 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	113'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	113

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 104 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From nA feet to nA feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 61 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 8888 (Contractor)
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed (By driller performing actual drilling on site or contractor)
Date 08-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627