

OFFICE USE ONLY
 Log No. 39521
 Permit No. _____
 Basin. 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19365

1. OWNER ROSS, Brent ADDRESS AT WELL LOCATION # 3 HALL LN
 MAILING ADDRESS 14 N. Hwy 95 A VERMONT, NV 89447
 2. LOCATION SE 1/4 SE 1/4 Sec. 16 T. 14 S. R. 25 E. Lyon County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 14-231-24 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sandy Coarse Sand				
Gravel		5	35	30
Brown Clay		35	38	3
Coarse Sand				
Gravel		38	48	10
Brown Clay		48	50	2
Coarse Sand				
Gravel		50	58	8
Brown Clay, Coarse Sand & Gravel		58	70	12
Coarse Sand		70	72	2
Brown Clay				
Coarse Sand		72	81	9
Coarse Sand				
Gravel & Small Rock		81	112	31
Coarse Sand		112	122	10
Brown Clay, Coarse Sand & Gravel		122	131	9
Fine to Coarse Sand		131	136	5
Coarse Sand, Clay & Gravel	X	136	142	6
Coarse Sand & Gravel Strata	X	142	159	17

8. WELL CONSTRUCTION
 Depth Drilled 159 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 159 Feet
 From 0 Feet To 159 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>±1</u>	<u>159</u>

Perforations:
 Type perforation Sawed
 Size perforation 1 1/2 x 3" x 6 rows
 From 139 feet to 159 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 159 feet

9. WATER LEVEL
 Static water level 35' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.4 °F Quality Good

Date started 7-9 1992
 Date completed 7-13 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>2</u>	<u>1/2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. B/Beer Lane Contractor
Vermont Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Lay Ogden
 By driller performing actual drilling on site or contractor
 Date 7-28-92