

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19364
26 West Ward

1. OWNER Ivan + Carole Stephens ADDRESS AT WELL LOCATION Yerington Nev 89447
MAILING ADDRESS P.O. Box 583
Yerington Nev 89447

2. LOCATION N1/4 SW 1/4 Sec. 27 T. 14 S. R. 25 E. Lyon County
PERMIT NO. 14-271-44 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse Sand				
Gravel + Rock		0	76	76
Gravel + Rock		76	80	4
Coarse Sand				
Gravel + Rock		80	97	17
Coarse Sand				
Gravel + Clay		97	98	1
Coarse Sand				
Gravel + Rock		98	130	32
Coarse Sand				
Gravel + Clay		120	126	6
Coarse Sand				
Gravel + Rock		126	136	10
Gravel + Rock		136	141	5
Coarse Sand				
Gravel + Rock	X	141	155	14
Coarse Sand				
Gravel + Clay		155	160	5
Coarse Sand				
Gravel + Rock	X	160	164	4
Coarse Sand				
Gravel + Few Rock	X	164	183	19

Plugged By Well
Log 126163

8. WELL CONSTRUCTION
Depth Drilled 183 Feet Depth Cased 184 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10 9/8</u>	0		183	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>183</u>

Perforations:

Type perforation Sawed
Size perforation 10 x 3/4 x 6 holes

From	feet to	feet
<u>163</u>	<u>183</u>	

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 183 feet

9. WATER LEVEL
Static water level 112.6" feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 64 °F Quality Good

Date started 6-29-92
Date completed 7-3-92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>25</u>	<u>3</u>	<u>1/2 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling Contractor
Address 162 N. ByBee Lane Contractor
Yerington NEV 89447

Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed John Ogden
By driller performing actual drilling on site or contractor
Date 7-28-92