

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11366

PRINT OR TYPE ONLY

1. OWNER Rocky And Sandy Stull ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 262 Mustang Court
Round Mountain NV 89045

2. LOCATION SW 1/4 SE 1/4 Sec 4 T. 10 N. R. 43 E Nye County
PERMIT NO. 12-461-11 Parcel No. _____ Subdivision Name Sanita Court

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation
Municipal Industrial Test
Stock Other

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	25 5	5
Clay		5	9	4
Large gravel		9	22	13
Grey clay		22	30	8
Large gravel		30	65	35
Brown clay		65	67	2
sd + gravel		67	85	18
Brown clay		85	90	5
Sand		90	94	4
Brown clay		94	115	21
Large gravel	✓	115	130	15
Grey clay		130	135	5

'92 SEP 11 AID:41
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 135 feet
8 3/4 inches
_____ inches

Casing record _____
Weight per foot 12.81 Thickness .188

Diameter	From	To
<u>6</u> inches	<u>+1</u> feet	<u>135</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type NEAT Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation milled slot
Size perforation 1/8 x 3
From 120 feet to 130 feet
From _____ feet to _____ feet

Date started 8-25, 1992
Date completed 8-26, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Lift

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 14 feet below land surface
Flow 30 G.P.M. _____ P.S.I.
Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Woytel Drilling Co. Contractor
Address 2220 Stowe Dr. Reno NV 89511 Contractor
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Woytel By driller performing actual drilling on site or contractor
Date 9-3-92