

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31192
 ADDRESS AT WELL LOCATION Eureka High School

1. OWNER Eureka School Dist ADDRESS AT WELL LOCATION Eureka High School
 MAILING ADDRESS Box 249 Eureka Nev
89316

2. LOCATION SE 1/4 NW 1/4 Sec 14 T 19 N S R 53 E Eureka County
 PERMIT NO. WFO 573 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE WATER EXTRACTION
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Aspirator

6. LITHOLOGIC LOG vw-4

Material	Water Strata	From	To	Thick-ness
<u>Silty gravel 6m</u>		<u>0</u>	<u>22'</u>	<u>22'</u>
<u>Clayey sand</u>		<u>22'</u>	<u>40'</u>	<u>18'</u>
<u>Dark brown</u>				
<u>Native Decomposed</u>		<u>40'</u>	<u>55'</u>	<u>15'</u>
<u>tuft</u>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
6 Inches 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>3</u>		<u>Sch. 40</u>	<u>0</u>	<u>55</u>

Perforations:
 Type perforation factory slot
 Size perforation .020
 From 25 feet to 55 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 13' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 13 feet to 55 feet

Date started 8/15 1992
 Date completed 8/16 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>11</u>	<u>11</u>	

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Anderson
 Address (635 Belford RD) Reno Nev
 Contractor

Nevada contractor's license number 34525
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1028
 Division of Water Resources, the on-site driller

Signed Paul Anderson
 By driller performing actual drilling on site or contractor

Date 8/31/92

192 SEP -3 11:02
 STATE ENGINEER