

OFFICE USE ONLY
 Log No. 39543
 Permit No. 219
 Basin 7
 NOTICE OF INTENT NO. 10040

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Fred L or Margaret Miller ADDRESS AT WELL LOCATION End of Kittridge Canyon Rd Lot 7
 MAILING ADDRESS 383 West Berry Crk pl Spring Creek ELKO NV 8

2. LOCATION NE 1/4 SW 1/4 Sec 33 T 35 N/S R 55 E ELKO N.U. County
 PERMIT NO. 37-008-04-2 Kittridge CANYON Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	1	1
CLAY Hard PAN		1	18	17
Sus FISH SANDSTONE		18	225	207
CLAY Blond color		225	272	47
Loose SANDSTONE	Water	272	310	38
Gravel				

8. WELL CONSTRUCTION
 Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10</u> Inches	<u>0</u> Feet	<u>55</u> Feet	
<u>9</u> Inches	<u>55</u> Feet	<u>310</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>310</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3

From	feet to	feet
<u>245</u>	<u>310</u>	
From	feet to	feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 55 feet to 310 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Good of Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fentig Drilling Co Contractor
 Address PO Box 525 Contractor
ELKO NV 89803
 Nevada contractor's license number 31904 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shorel Fentig
 By driller performing actual drilling on site or contractor
 Date 9-23-92

Date started 9-11 1992
 Date completed 9-21 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>36</u>	<u>200</u>	<u>8</u>

RECEIVED
 STATE ENGINEERS OFFICE
 '92 SEP 29 AM 11:11