BW-28

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39561
Permit No.
Basin 61

NOTICE OF INTENT NO. 17971

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS PO BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NE ¼ Sec. 24 T 36 N/S R 49 E EUREKA County
PERMIT NO. 55142 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY ROCK		0	90	90
BROWN ROCK & CLAY		90	130	40
BLACK ROCK & CLAY		130	220	90
BLACK ROCK		220	360	140
BLACK ROCK &CLAY		360	440	80
BLACK FRACTURED ROCK		440	570	130
BLACK ROCK & CLAY		570	640	70
BLACK ROCK		640	730	90
GREY ROCK		730	800	70
BLACK ROCK		800	910	110
BLACK FRACTURED ROCK		910	1040	130
BLACK ROCK W/CALCITE		1040	1130	90
BLACK ROCK		1130	1650	520
BLACK ROCK WITH FRAC.		1650	1770	120
GREY FRACTURED ROCK		1770	1940	170
BLACK ROCK		1940	2120	180

Date started AUGUST 6, 1992
Date completed SEPTEMBER 5, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2120 Feet Depth Cased 2090 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	100	Feet
31	Inches	0	Feet	2120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	159	.375	0	100
24	95	.375	0	2090

Perforations:
Type perforation LOUVERED
Size perforation 1/8" X 2-1/2"
From 210 feet to 250 feet
From 570 feet to 610 feet
From 930 feet to 970 feet
From 1290 feet to 1330 feet
From 1650 feet to 2050 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 130 feet to 2120 feet

9. WATER LEVEL
Static water level 560 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 130 °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed Victor Hernandez (By driller performing actual drilling on site or contractor)
Date SEPTEMBER 7, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627