WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 31510
Permit No.
Basin 70

NOTICE OF INTENT NO. 19943

1. OWNER Stephen B Hall
MAILING ADDRESS P.O.Box 3203
Winnemucca, Nev. 89446

ADDRESS AT WELL LOCATION
Davis Lane
Winnemucca, Nevada 89446

2. LOCATION NW ¼ NW ¼ Sec. 11 T. 35 X N/S R. 37 E. Humboldt County

PERMIT NO. - (Issued by Water Resources) | 13-361-29 (Parcel No.) | - (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 48 | 48 |
| Sand & Gravel | | 48 | 83 | 35 |
| Sandy Clay | | 83 | 90 | 7 |
| Sandy & Gravel | X | 90 | 130 | 40 |

'92 OCT 23 A11:29
STATE ENGINEER

Date started 10-16, 1992
Date completed 10-16, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 75 | | air on rig |

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 ¼ Inches | | 0 Feet | 130 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 90 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8 X 3
From 90 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.Box 590 (Contractor)
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1536
Signed C. E. Eyla (By driller performing actual drilling on site or contractor)
Date 10-21-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627