WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39573
Permit No.
Basin 71 · GRASS V.

NOTICE OF INTENT NO. 20815

1. OWNER Shayne Vanlandingham
MAILING ADDRESS 8525 Stinson Wmca., Nv. 89445
ADDRESS AT WELL LOCATION same

2. LOCATION N W ¼ S W ¼ Sec. 24 T. 35 N N/S R. 37 E E. Humboldt County
PERMIT NO. (Issued by Water Resources) | Parcel No. N/A | Subdivision Name N/A

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Brown		0	2	2
Clay Brown		2	5	3
Gravely Clay Brown		5	15	10
Gravel Brown		15	60	45
Gravely Clay Brown		60	110	50
Sand + Gravel Brown	15	110	125	
Clay Brown		125	135	10
Sand + Gravel Brown	15	135	150	

'92 SEP 25 P2:29
STATE ENGINEER'S OFFICE

Date started 8-18- 1992
Date completed 8-25- 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	4	2½

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	150

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 100 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T + R DRILLING (Contractor)
Address P. O. Box 1982 Wmca., Nv 89446 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-22-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627