

OFFICE USE ONLY
 Log No. 37575
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 19658

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Resolution Trust Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2910 N 44th. St 1910 Morgan
Phoenix, AZ 85018 Lot 134 Bk M
 2. LOCATION NE 1/4 NE 1/4 Sec 5 T. 17 N/S R. 21 E Storey County _____
 PERMIT NO. 03-111-25 - Virginia City Highlands Unit # 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	8	8
Brown tan clay & rock mixed		8	12	4
Blue gray volcanic rock		12	40	28
Soft blue grey rock				
little blue grey clay stone		40	150	110
Green & bluish grey clay stone		150	170	20
Bluish grey rock & clay stone with specs and coarse sands		170	198	28
Green white specs		198	225	27
Purple white specs		225	237	12
Green & bluish grey mixed		237	250	13
Green some purple & red		250	310	60
Purple white specs little green white chips multi-colored sands		310	330	20
Green & purple mixed with white specs	X	330	399	69
T.D. 399 ft				

8. WELL CONSTRUCTION
 Depth Drilled 399 Feet Depth Cased 399 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 399 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	399

Perforations: factory
 Type perforation _____
 Size perforation 3/32 X 3
 From 320 feet to 340 feet
360 feet to 380 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 399 feet

9. WATER LEVEL
 Static water level 185 99 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date 4/27/92

Date started 11/17/92 19_____
 Date completed 12/01/92 19_____
 STATE ENGINEER RECEIVED

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bail <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2</u>