WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39582
Permit No.
Basin 87

NOTICE OF INTENT NO. 18839

1. OWNER SEA Consulting Eng. Inc.
MAILING ADDRESS 950 Industrial Way
Sparks, NV 89431-6092

ADDRESS AT WELL LOCATION Downtown Reno
Plaza & Center, Commercial/Lake
Reno, NV

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. M/O 483 NE well (Issued by Water Resources) | Parcel No. | Downtown Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt concrete		0	2"	2"
Base		2"	6"	4"
Moist, compact gray cobbly clayey sand with est. 15% low plastic fines, 55% sand, 30% gravel to 3"		6"	18"	12"
Brown, slightly clayey very cobbly gravelly sand, with est 10-15% fines.		1.5'	18'	16.5'
Brown clayey cobbly sand with est 10-15% fines		18'	21'	3'
Brown slightly clayey gravelly sand with est. 5-10% fines occasional cobbles		21	31	10
Grey gravelly sand with est. 90% medium-coarse sand 10% rounded gravel to 1" diameter		31	34	3

Date started 12/3/91, 19
Date completed 12/3/91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	34 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	34
4" PVC end cap				
4" PVC locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1½ x 6 rows
From 23 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2' BENTONITE 16'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 21 feet to 34 #3 sand feet

9. WATER LEVEL
Static water level 25.34 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date September 15, 1992

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627