WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39590
Permit No.
Basin 87

NOTICE OF INTENT No. 21651

1. OWNER Simon Hydro-Search
MAILING ADDRESS 5250 South Virginia St.
Reno, NV. 89502

ADDRESS AT WELL LOCATION Reno Rent
1920 Glendale Ave
Sparks, NV. 89431

2. LOCATION SW ¼ NW ¼ Sec. 8 T 19 N/S R 20 E Washoe County
PERMIT NO. M/O-525 MW-3 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly boulder sand		0	5.0'	5.0'
Silty gravelly sand		5.0	7.0'	2.0'
Gravelly boulder sand		7.0	49.0'	42.0'

'92 OCT 23 A11:24
STATE ENGINEER

Date started 9/2/92, 19
Date completed 9/2/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 49.0 Feet Depth Cased 49.0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	49.0 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40 PVC	0	49.0

Perforations:
Type perforation factory sawed slot
Size perforation 0.040"
From 18.5 feet to 49.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 11.9'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 15.5' feet to 49.0' feet

9. WATER LEVEL
Static water level 29.06 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature — " °F Quality "

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Gary C. Holmes (By driller performing actual drilling on site or contractor)
Date October 14, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627