WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39600
Permit No.
Basin 88

NOTICE OF INTENT NO. 19669

1. OWNER Wm David Jeremy Marshall-Gratrix
MAILING ADDRESS 230 East Laramie/ Box 18553 Reno, Nv 89511
ADDRESS AT WELL LOCATION 230 East Laramie

2. LOCATION SW ¼ NW ¼ Sec. 8 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. — (Issued by Water Resources) Parcel No. 50-132-06 Subdivision Name Pleasant Valley

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Green rock traces of				
white & green gray				
clay little white				
rocks		160	200	40
Green & black rock				
sands white & yellow				
green clay		200	215	15
Mostly black with				
light green mixed in		215	297	82
Mostly clay		297	308	11
Gray green clay				
white & rock mixed		308	354	46
T.D. 354 ft				

'92 SEP 17 A10:24
STATE ENGINEER'S OFFICE

Date started 6/8/92, 19
Date completed 6/10/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2½

8. WELL CONSTRUCTION
Depth Drilled 354 Feet Depth Cased 354 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		160 Feet	354 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	134	354

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 314 feet to 334 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal refer to original log
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 6/16/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627