WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39606
Permit No.
Basin 92A

NOTICE OF INTENT NO. 20690

1. OWNER Gladys McDaniel
MAILING ADDRESS 10130 Manassas Dr.
Reno, NV 89506

ADDRESS AT WELL LOCATION
10130 Manassas Dr.
Reno, NV 89506

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County

PERMIT NO. ____ Issued by Water Resources | 86-225-15 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy d.g.		70	86	16
Black clay w/ sm. rock		86	88	2
Sand with clay		88	98	10
Sand and d.g.very soft		98	140	42
at bottom.				

'92 SEP 16 A11:04
STATE ENGINEER'S OFFICE

Date started 9-9, 19 92
Date completed 9-9, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	~~140~~ 123	1½ hrs

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		70 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	60	140

Perforations:
Type perforation saw cut
Size perforation 3½ x 3 single row
From 60 feet to 70 feet
From 130 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 59 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 Fallon, NV 89406 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed D.C. Biffle (By driller performing actual drilling on site or contractor)
Date 9-9-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627