WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39609
Permit No.
Basin 92B

NOTICE OF INTENT NO 21642

1. OWNER LEE MAYO
MAILING ADDRESS 3460 Rolling Ridge Road
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ NE ¼ Sec 14 T 20N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 082-511-09 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Milled out steel at bottom of well				
Brown to red, volcanic rock		106	150	44
Gray hard granite		150	165	15
Small fracture	X	165	166	1
Gray hard granite with small red streaks of volcanics		166	186	20
Fracture	X	186	187	1
Gray granite		187	205	18
Fracture	X	205	207	2
Gray granite		207	235	28
Fracture	X	235	236	1
Gray granite		236	251	15

Date started 9-16-92, 19
Date completed 9-17-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE
'92 SEP 22 AM 10:30

8. WELL CONSTRUCTION
Depth Drilled 251 Feet Depth Cased 251 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		106 Feet	251 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		.188	0	251

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 186 feet to 246 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 251 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow 55 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 18, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627