WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39617
Permit No.
Basin 101

NOTICE OF INTENT NO. 21437

1. OWNER Help -U-Sell Realty/Gary Hutchings
MAILING ADDRESS 710 W. Williams Ave
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4115 Cimmaron Road
Fallon, NV 89406

2. LOCATION NE ¼ NE ¼ Sec. 33 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 008-691-87 (Parcel No.) Pheasant Green (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 12 | 12 |
| Brown Clay | | 12 | 16 | 4 |
| Brown Coarse Sand | | 16 | 25 | 9 |
| Brown Fine sand | | 25 | 30 | 5 |
| Brown Coarse Sand | | 30 | 39 | 9 |
| Fine Brown Sand | | 39 | 41 | 2 |
| Black & Green Coarse Sand | | 41 | 48 | 7 |
| Black Sand Clay | | 48 | 56 | 8 |
| Black & Green Coarse Sand | | 56 | 61 | 5 |
| Brown Clay | | 61 | 64 | 3 |
| Brown Coarse Sand | X | 64 | 84 | 20 |

Date started October 21, 1992
Date completed October 21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 84 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 84 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 84 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 178"
From 80 feet to 83 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 84 feet

9. WATER LEVEL
Static water level 13' 3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date Oct 23, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627