

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22261

1. OWNER JOHN BUSCHIAZZA ADDRESS AT WELL LOCATION 821 BUCKSKIN GARDNERVILLE, NV  
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SW 1/4 SW 1/4 Sec 18 T. 12 N. S. R. 21 E. DOUGLAS County  
 PERMIT NO. 29-530-10 Parcel No. RUHENSTROTH Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	88	88
CLAY		88	115	27
SANDY CLAY		115	142	27
CLAY		142	153	11
SANDY CLAY		153	181	28
SAND		181	189	8
SANDY CLAY		189	204	15
CLAY		204	211	7
SANDY CLAY		211	240	29
COARSE SAND + CLAY		240	276	36
CLAY		276	330	24
COARSE SAND + GRAVEL	✓	330	375	45

92 SEP 21 P2:15  
 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 375 Feet Depth Cased 375 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches. 0 Feet 360 Feet  
5 5/8 Inches. 360 Feet 375 Feet  
 \_\_\_\_\_ Inches. \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>360</u>
<u>5</u>	<u>11</u>	<u>.188</u>	<u>360</u>	<u>375</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 260 feet to 280 feet  
 From 340 feet to 360 feet  
 From 360 feet to 375 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 360 feet

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 8-27, 1992  
 Date completed 9-11, 1992

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore  
 By driller performing actual drilling on site of contractor  
 Date 9-12-92