WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39638
Permit No.
Basin 108

NOTICE OF INTENT NO. 19166

1. OWNER Gene Adrian
MAILING ADDRESS 506 Madden Cir
Yerington NV 89447

ADDRESS AT WELL LOCATION Parcel B
A Menette Way
Yerington NV 89447

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. None (Issued by Water Resources) | Parcel No. | Subdivision Name: Sunset Hills

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Gravel		0		20
pea gravel		20		40
pea gravel		40		60
pea gravel		60		80
Brn clay-gravel		80		100
gravel	✓	100		120
gravel	✓	120		140
gravel	✓	140		150
gravel	✓	150		

92 SEP 24 A9:56 STATE ENGINEER

Date started 9/17/92, 19
Date completed 9/20/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	150 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	150

Perforations:
Type perforation Factory Slot
Size perforation 3/32 x 3"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 73' feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller (Contractor)
Address By 92 Smith NV 89430 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T
Signed Jeff Steele (By driller performing actual drilling on site or contractor)
Date 9/26/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627