

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39645
Permit No. 57057
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT 10736

1. OWNER MARK GRIFFITH ADDRESS AT WELL LOCATION _____
MAILING ADDRESS _____
2. LOCATION NW 1/4 NE 1/4 Sec. 14 T. 19 N. R. 60 E County _____
PERMIT NO. 57057 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>CLAY + CALICHE</u>		<u>0</u>	<u>60</u>	<u>60</u>
<u>CLAY, CALICHE w/ STREAKS OF BROWN LIME.</u>		<u>60</u>	<u>400</u>	<u>340</u>
<u>CLAY AND POPAON CALICHE</u>		<u>400</u>	<u>450</u>	<u>50</u>

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches 0 Feet 450 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>71</u>	<u>450</u>

Perforations:
Type perforation FACTORY
Size perforation 18 x 8
From 410 feet to 430 feet
From 370 feet to 390 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 450 feet

9. WATER LEVEL
Static water level 144 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING Contractor
Address 6475 GARY AVE Contractor
LAS VEGAS, NEVADA 89139
Nevada contractor's license number issued by the State Contractor's Board: 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1594
Signed Toddell Coull
By driller performing actual drilling on site or contractor
Date 9-22-92

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____

RECEIVED
SEP 28 1992

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-18 1992
Date completed 9-22 1992