WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39648
Permit No. 54633
Basin 212

NOTICE OF INTENT NO. 10507

1. OWNER Leonard Zeedyk Jr.
MAILING ADDRESS 1340 Pinto Rock Ln. #102
LV NV 89128

ADDRESS AT WELL LOCATION N/A

2. LOCATION NW ¼ SE ¼ Sec. 6 T. 20 N/S R. 60 E. Clark County

PERMIT NO. 54633 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	28	
Cemented Gravel		28	32	
Clay Gravel		32	160	
Cemented Gravel		160	185	
Clay & Gravel		185	485	
Gravel & Water	xx	485	505	
Cemented Gravel		505	525	
Clay & Gravel		525	565	
Gravel & Water	xx	565	610	

RECEIVED
OCT 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8/25/92, 19
Date completed 9/1/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased 610 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0 Feet	55 Feet
9 7/8" Inches	55 Feet	610 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	610

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 570 feet to 590 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 423 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada 89102

Nevada contractor's license number issued by the State Contractor's Board 10062

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed (By driller performing actual drilling on site or contractor)

Date 10/13/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627