WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39652
Permit No.
Basin 212

NOTICE OF INTENT NO. 10617

1. OWNER EG&G Remote Sensing
MAILING ADDRESS c/o Converse Consultants 4670 S. Polaris Ave. L.V., NV
ADDRESS AT WELL LOCATION EG&G Remote Sensing Laboratory Nellis AFB - Las Vegas

2. LOCATION SE ¼ NW ¼ Sec 2 T 20 N OR 61 E CLARK County

PERMIT NO. Mo-2197 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
AC		0	3	3
Sandy Gravel - Loose		3	6'	5'
Silty Sand		6	11	5'
Gravelly sand		11	16	5'
Silty Sand w/gravel		16	23	7'
Silty Sand - cemented w/ caliche gravel		23	31	8'
Sandy silt		31	33	2'
Same but cemented		33	40	7'
Silty Sand		40	42	2'
Same - cemented		42	50	8'
" - porous cemented		50	53	3'
Silty clay - STIFF		53	56	3'
Clayey Silt - "		56	62	6'
Silty clay - "		62	71	9'
Silty Sand - Dense		71	76.5	5.5'
Sandy Silt		76.5	92	15.5'
T.D = 91				

RECEIVED
NOV 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-21, 1992
Date completed 9-24, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 91 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	91 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	Sch. 40	0	90

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-67 / 65-67' Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 67 feet to 91 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This ~~well was~~ drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeDuc (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeDuc (By driller performing actual drilling on site or contractor)
Date 11-03-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627