WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39653
Permit No.
Basin 212

NOTICE OF INTENT NO. N917

1. OWNER EG&G LABORATORY
MAILING ADDRESS C/o CONVERSE CONSULTANTS 4670 S. POLARIS AVE. LAS VEGAS
ADDRESS AT WELL LOCATION EG&G SENSING LABORATORY NELLIS AFB - LAS VEGAS

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 20 N(S) R. 61 E. CLARK County
PERMIT NO. M0-2197 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	6.5	6.5'
Sandy gravel		6.5	8.5	2'
Silty sand w/ gravel		8.5	15	6.5'
Silty clay trace gravel		15	21	6'
Clayey silt w/ gravel		21	26	5'
Silty gravel cemented		26	31	5'
Sandy silt tr. gravel		31	36	5'
Clayey silt w/sand trace gravel		36	41	5'
Silty sand w/gravel		41	46	5'
Silty sand		46	51	5'
Sandy silt		51	56	5'
Clayey silt		56	60.5	4.5
Silty clay		60.5	63	2.5
Clayey silt		63	65.5	2.5
Silty clay		65.5	68	2.5
Sandy silt		68	70.5	2.5
Clayey silt tr. sand		70.5	74.5	4'
Silty clay w/gravel		74.5	78	3.5
Same no gravel		78	90	12'
T.D. = 90				

Date started 9-24, 19 92
Date completed 9-24, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
NOV 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	90 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7105	SCH. 40	0	90

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-68 ~~68-68~~ Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/Bent.
Gravel Packed: ☑ Yes ☐ No
From 68 feet to 90 feet

9. WATER LEVEL
Static water level 75' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 11-03-92

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627