WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39725 (in Book)
Permit No.
Basin

NOTICE OF INTENT NO. 11173

1. OWNER NDOT
MAILING ADDRESS C/O MARK GROUP 1919 S. Jones Blvd, Las Vegas
ADDRESS AT WELL LOCATION NDOT MAINTENANCE YARD GLENDALE, NEVADA.

2. LOCATION SW ¼ NW ¼ Sec. 2 T. 15 N/S R. 66 E. Clark County
PERMIT NO. Mo. 2135 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
gravelly sand		.5	3	2.5
Silty Sand w/gravel		3	4.5	1.5
Sand, gravel & clay		4.5	7	2.5
Sandy silt		7	8	1
Silty clay w/m sand		8	12.5	4.5
Sandy silt & clay		12.5	35	22.5

T.D = 35'

RECEIVED
NOV 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7-13, 1992
Date completed 7-13, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	35 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	Sch. 40	0	35
1"			0	35

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 10 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-8/6-8 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/Bent.
Gravel Packed: ☑ Yes ☐ No
From 8 feet to 35 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc (Contractor)
Address 4670 S. Polaris (Contractor)
Las Vegas, Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M. 1817
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 11-10-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627