WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39742
Permit No.
Basin 04-059 - Lower Reese

NOTICE OF INTENT NO. 8428

1. OWNER Mt State Mineral Enterprises ADDRESS AT WELL LOCATION
MAILING ADDRESS 4376 So Fremont
Tucson AZ 85714

2. LOCATION ~~SW~~ ¼ ~~NW~~ ¼ Sec. 33 T. 33 N/S R. 48 E County
PERMIT NO. NW NE (LOT 2)
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	13	13
Rock - Sand		13	84	
Sandy Clay		84	160	
Some Rock				
Boulder & Sand		160	220	
Sand Gravel		220	230	
Gravel + Sand		230	255	
Clay		255	260	
We advised to Plug By Tom Gallagher				
Plugged well				
Pump so vis mud from				
Bottom to top.				
Run 60' 2" pipe				
Pump Neat Cement 60'				
to Surface				

Date started 7-7-92, 19
Date completed 7-17-92, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		4

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	260

Perforations:
Type perforation FACT
Size perforation 1/8 X 3
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to SURFACE feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling Contractor
Address 181-14 Bullion Rd Contractor
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
Signed Shane Bennett
By driller performing actual drilling on site or contractor
Date 8-16-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627