

OFFICE USE ONLY
 Log No. 39749
 Permit No. 71
 Basin. 71

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22384

1. OWNER Clifford Burns ADDRESS AT WELL LOCATION Eagle + Dove St.
 MAILING ADDRESS 335 W. 4th St. Wmca., Nv. 89445

2. LOCATION R e 1/4 S e 1/4 Sec 8 T 34 N N/S R 38 e E Perishing County
 PERMIT NO. Block F lot #1 Parcel No. Burns Acres P. U. D. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil Brown		0	2	2
Clay Brown		2	4	2
Gravelly Clay Brown		4	16	8
Gravel Brown Large		16	54	38
Gravel Brown		54	67	13
Gravelly Clay Brown		67	86	19
Clay with strips of Sand + Gravel Brown	24	86	110	

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>6</u> Inches	<u>50</u> Feet <u>110</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>14</u>	<u>.188</u>	<u>0</u>	<u>110</u>

Perforations:
 Type perforation Torch
 Size perforation 1/8" by 5"
 From 85 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T + R DRILLING Contractor
 Address P.O. Box 1982 Wmca., Nv. 89446 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 017721
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
 Signed Thomas Sts
 By driller performing actual drilling on site or contractor
 Date 10-14-92

Date started 9-22, 1992
 Date completed 9-30, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>2 1/2</u>

92 NOV -2 P 2:56
 RECEIVED
 STATE ENGINEERS OFFICE