

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 39753
 Permit No. 97
 Basin. TH-5
 NOTICE OF INCIDENT NO. 20759

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER WASHOE COUNTY UTILITY ADDRESS AT WELL LOCATION.....
 MAILING ADDRESS DIVISION
Box 11130 Reno, NV 89520
 2. LOCATION NE 1/4 SW 1/4 Sec 14 T. 18 S. R. 19 F. WASHOE County
 PERMIT NO. 57162 NA Parcel No. NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDS, GRVLS, COBBLES, Boulders		0	85	85
SANDS, GRVLS, SILTS		85	155	70
SILTY CLAY		155	200	45
TRUCKEE FM SILTSTONE		200	400	200
CLAY, ALTERED VOLCANICS		400	575	175
ANDESITE		575	630	55

8. WELL CONSTRUCTION
 Depth Drilled 630 Feet Depth Cased 605 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 3/4 Inches To 0 Feet 630 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/2</u>		<u>1/4</u>	<u>4</u>	<u>605</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3 x 3/32
 From 357 feet to 605 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 630 feet

9. WATER LEVEL
 Static water level 148 feet below land surface
 Artesian flow NO G.P.M. ? P.S.I.
 Water temperature 60.0 °F Quality ?

Date started 8/5 1992
 Date completed 8/19 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20±</u>		<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address Box 21548 Contractor
CARSON CITY, NV 89721
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Joe Reisek
 By driller performing actual drilling on site or contractor
 Date 11/20