

OFFICE USE ONLY
 Log No. 39768
 Permit No. 87
 Basin 87
 NOTICE OF INTENT NO. 21728

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ed Autler ADDRESS AT WELL LOCATION 555 Orrcrest
 MAILING ADDRESS 555 Orrcrest
Reno, Nv 89506

2. LOCATION NW 1/4 NW 1/4 Sec. 26 T 20 N/S R 19 E Washoe County
 PERMIT NO. 03-085-04 - Off Parr Blvd

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Calitchie clay		0	39	39
Gravels & clay		39	73	34
Multi-colored rock mainly black material fractured [Red & white]		73	92	19
Gray rock medium hard with clay stringers and some soft white clay		92	126	34
Gray specked rock with some gray clay & white soft clay		126	129	3
Hard gray rock		129	157	28
T.D. 157 ft				

8. WELL CONSTRUCTION
 Depth Drilled 157 Feet Depth Cased 157 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10 5/8	0	50		
8 1/2	50	157		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	157

Perforations:
 Type perforation factory
 Size perforation 3/32" X 3

From 117 feet to 137 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 157 feet

9. WATER LEVEL
 Static water level feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature cold °F Quality clear

Date started 9/7/92, 19.....
 Date completed 9/8/92, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	30		1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.

Signed Roger M Thrall
 By Driller performing actual drilling on site or contractor

Date Roger M. Thrall 9/10/92