

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21195

1. OWNER Boon Tamen Hotel ADDRESS AT WELL LOCATION Boon Tamen Hotel  
 MAILING ADDRESS P.O. Box 389 Reno NV T-807 Carson Ranch

2. LOCATION Sec. 14 NE 1/4 Sec. 16 T. 19 N. R. 18 E. Washoe County

PERMIT NO. M.D. 52413 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE Water Extension  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG W-24

Material	Water Strata	From	To	Thick-ness
<u>Clayey Sand</u>	<u>Md</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>Sandy Gravel</u>	<u>Ms</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>Silty Sand</u>	<u>Pd</u>	<u>10</u>	<u>20</u>	<u>10</u>
<u>Silty Gravelly Sand</u>	<u>Md</u>	<u>20</u>	<u>30</u>	<u>10</u>
<u>Loamy Silty Sand</u>	<u>Ms</u>	<u>30</u>	<u>40</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 38 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 3 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch. 40</u>	<u>steel pipe</u>	<u>0</u>	<u>38</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation 1/2" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 13 feet to 38 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 11 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 11 feet to 38 feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9-16 1992  
 Date completed 9-16 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name Andrew Drilling Contractor  
 Address 1635 Bedford Rd. Reno NV 89509  
 Nevada contractor's license number 34525 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed Andrew Drilling  
 By driller performing actual drilling on site or contractor  
 Date 10/20/92