

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2195

1. OWNER Parrotta Hotel ADDRESS AT WELL LOCATION Parrotta Hotel
 MAILING ADDRESS 1600 Ave 300 2-80 & Carson Blvd

2. LOCATION Sec 16 T. 19 N. R. 15 E. Washoe County
 PERMIT NO. me 52110 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Water Extraction WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Other

6. LITHOLOGIC LOG W-30

Material	Water Strata	From	To	Thick-ness
<u>S. Fly Sand</u>	<u>No</u>	<u>0</u>	<u>5.0</u>	<u>5.0</u>
<u>Clayey Sand</u>	<u>No</u>	<u>5.0</u>	<u>10.0</u>	<u>5.0</u>
<u>Sandy Clay</u>	<u>No</u>	<u>10.0</u>	<u>15.0</u>	<u>5.0</u>
<u>Sandy clay</u>	<u>No</u>	<u>15.0</u>	<u>20.0</u>	<u>5.0</u>
<u>Sandy clay</u>	<u>No</u>	<u>20.0</u>	<u>30.0</u>	<u>10.0</u>
<u>Clayey Colloidal Sand</u>	<u>No</u>	<u>30.0</u>	<u>40.0</u>	<u>10.0</u>

02 NOV 16 21:31

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
8 Inches 0 Feet 10 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Sk 40</u>	<u>Steel Pipe</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation Factory Slot
 Size perforation 1/2" x 3"
 From _____ feet to _____ feet
 From 15 feet to 40 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 13 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 13 feet to 40 feet

9. WATER LEVEL
 Static water level 12.17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Drilling
 Address 1635 Bedford Rd., Reno Nev. 89509
 Nevada contractor's license number 34525 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Andrew Drilling by driller performing actual drilling on site or contractor
 Date 10/20/92

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			