WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39797
Permit No.
Basin 102

NOTICE OF INTENT NO. 1669

1. OWNER Ted Hodge
MAILING ADDRESS Same as well location
ADDRESS AT WELL LOCATION Village Market 2900 Nevada Ave Silver Springs NV 89429

2. LOCATION SW ¼ SW ¼ Sec 19 T 18 N/S R 25 E Lyon County
PERMIT NO. M/O 555 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MWJ

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt + Base Material | No | 0 | 1 | 1 |
| Silty Clayey Sand | No | 1 | 4 | 3 |
| Clayey Silt | No | 4 | 23 | 19 |
| Fine Grain Sand | No | 23 | 35 | 12 |
| Gravelly Sand | Yes | 35 | 40 | 5 |
| Silty Clay | Yes | 40 | 50 | 10 |

Date started 6-2, 1992
Date completed 6-3, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 50 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | Sch. 40 | PVC | 0 | 50 |
| | | | | |

Perforations:
Type perforation Factory Slot
Size perforation .020
From feet to feet
From 35 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 33
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 33 feet to 50 feet

9. WATER LEVEL
Static water level 40.0 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Drilling Contractor
Address 1635 Bellford RD Contractor
Reno NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/20/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627