WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

'RINT OR TYPE ONLY
) NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39800
Permit No.
Basin 105

NOTICE OF INTENT NO. 20913

1. OWNER Mimi Job
MAILING ADDRESS 210 Autumn Hills Gardnerville NV
ADDRESS AT WELL LOCATION 210 Autumn Hills, Gardnerville, NV

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-051-20 (Parcel No.) Foothill (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Const Fill | | 0 | 2 | 2 |
| V Large Bldrs in DG | | 2 | 36 | 34 |
| DG, coarse, few clay beds, v thin | | 36 | 165 | 129 |
| DG, altered some O2 stains, few large cobbles, AB DG sands | X | 165 | 225 | 60 |

Abandon existing well with ripper, cement seal w bentonite pellets at bottom 5 ft. fill casing w cement grout.

'92 DEC -7 P2 STATE ENGINEER

Date started 10/3, 1992
Date completed 10/7, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20± | | 4 |

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From 0 Feet To 225 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6⅝ | | .188 | +2 | 225 |

Perforations:
Type perforation Sawcut
Size perforation 3X 3/32
From 165 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 163 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address Box 21548 (Contractor)
Carson City, NV 89728
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joseph F. Leisch (By driller performing actual drilling on site or contractor)
Date 12/4/92

(Rev. 1-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627