

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22411  
 ADDRESS AT WELL LOCATION 772 Mustang Gardnerville NV

1. OWNER Greg Davies Const (Builder)  
 MAILING ADDRESS 772 Mustang Gardnerville NV  
 2. LOCATION NW 1/4 NE 1/4 Sec. 24 T. 120 N. R. 26 E. Douglas County  
 PERMIT NO. 29-462-52 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ small gravels		0	10	10
Brown Sandy Clay		10	25	15
1/4' Gravels		25	30	5
Brown Clay w/ 3/8 gravel seams		30	65	35
Brown gummy clay		65	115	50
Black & Red Volcanic Rock		115	135	20
Brown Clay		135	140	5
3/8 Gravels w/ water	XX4	140	190	50

NOV 13 1992 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 5 5/8 Inches  
 From 190 Feet To 135 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 1/2 x 3 3/4  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 55  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 55 feet to 190 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature Cold °F Quality Good

Date started \_\_\_\_\_, 19\_\_\_\_  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>20'</u>	<u>3 hr.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A. S. H. BERRY CO. Contractor  
 Address 554 Hwy. 50 East #3  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed Joe Butts  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_