WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39809
Permit No.
Basin 108
NOTICE OF INTENT NO. 19370

1. OWNER Richard + Becky Goodwill
MAILING ADDRESS P.O. Box 563 Yerington Nev 89447
ADDRESS AT WELL LOCATION 486 Hwy 339 Yerington Nev 89447

2. LOCATION SE ¼ SW ¼ Sec. 4 T. 12 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 12-211-14 (Parcel No.) Parcel #1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil (Sandy Clay)		0	3	3
Brown Clay		3	10	7
Coarse Sand		10	18	8
Coarse Sand + Gravel (Blackish)		18	23	5
Coarse Sand + Gravel + Clay		23	25	2
Coarse Sand + Gravel		25	30	5
Coarse Sand, Gravel, + Small Rock		30	37	7
Coarse Sand, Gravel, + Rock		37	48	11
Coarse Sand		48	78	30
Bluesh Gray Clay + Sand		78	82	4
Brown Clay + Sand		82	86	4
Coarse Sand + Rock		86	92	6
Coarse Sandy Clay + Small Rock		92	98	6
Coarse Sand + Small Rock - Tight		98	116	18
Coarse Sand + Rock		116	119	3
Fine to Coarse Sand		119	139	20
Clay + Coarse Sand		139	141	2
Coarse Sand + Small Rock	X	141	143	2
Coarse Sand + Rock	X	143	146	3
Coarse Sand + Small Rock	X	146	162'6"	16'6"

Date started Aug 24, 1992
Date completed Aug 27, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	23	1/2

8. WELL CONSTRUCTION
Depth Drilled 162'6" Feet Depth Cased 163'6" Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	162'6" Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	162'6"

Perforations:
Type perforation Sawed
Size perforation 18 x 3" 6 Rows
From 142'6" feet to 162'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 162'6" feet

9. WATER LEVEL
Static water level 26' 10" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. ByBee Lane (Contractor) Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Gary Ogden (By driller performing actual drilling on site or contractor)
Date 9-3-92

RECEIVED NOV -3 '92 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627