

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20212

1. OWNER W.C. "DOC" GILES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 131 N. HWY 95 A
YERINGTON, NV 89447

2. LOCATION 1/4 Sec. 29 T 14 N N/S R. 25 E LYON County
 PERMIT NO. 14-271-19 SUBDIVISION NAME SUNSET HILLS
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND-SOME GRAVEL		0	20	
GRAVEL WITH SHORT SANDY CLAY		20	105	
SANDY CLAY SOME GRAVEL		105	115	
GRAVEL @ SHORT SANDY CLY STRIPS ^{WB}		115	127	
SANDY CLAY SOME GRAVEL ^{N 13}		127	135	
GRAVEL @ SHORT SANDY CLY STRIPS ^{N 13}		135	160	

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16"</u>		<u>188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 3/32 X 3"
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started 9-23, 1992
 Date completed 9-24, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature 60.0 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ed MILLER Contractor
 Address Box 92 Contractor
SMITH, NV 89444
 Nevada contractor's license number 32160
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller
 Signed JERRY PHINNEY
 By driller performing actual drilling on site or contractor
 Date 9 28 92