WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 39813
Permit No.
Basin 153

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

LOG REC'D 07/20/92
NOTICE OF INTENT NO. 8247

1. OWNER J and J MOYLE
MAILING ADDRESS EUREKA NEVADA 89316
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 23 N/~~S~~ 54 E EUREKA County
PERMIT NO. 29873 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other REVERSE

6. S and G. = ~~LITHOLOGIC LOG~~ Sand and Gravel

Material	Water Strata	From	To	Thickness
TOP SOIL		TOP	2	2
SAND		2	18	16
BLACK SAND CLAY		18	68	50
CLAY		68	72	4
BLACK SAND GRAVEL		72	76	4
CLAY		76	146	70
BLACK Sand GRAVEL	13	146	159	13
CLAY		159	164	5
BLACK S and G.	20	164	184	20
CLAYS, White and B.		184	345	161
S and G.	6	345	351	6
CLAY		351	370	19
CHippy Sand STONE	20	370	390	20
CLAY		390	407	17
CEMENED GRAVEL	9	407	416	9
CHIPPY SANDSTONE	7	416	423	7
CLAY & SAND		423	426	3
CLAY		426	440	14
S and G.	5	440	445	5
CLAY		445	459	14
Dirty S and G.	10	459	469	10
CLAY		469	479	10
Sand and Clay.	4	479	483	4
CLAY		483	493	10

Date started 4-10-92, 19
Date completed 7-4-92, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	950	120	120

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 29 inches Total depth 493 feet
Casing record 16" and 12"
Weight per foot Thickness ¼"

Diameter	From	To
16" inches	TOP feet	307 feet
12" inches	307 feet	493 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 FEET feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 493 feet

Perforations:
Type perforation ROSCO MOSS ⅛"
Size perforation
From 148 feet to 188 feet
From 330 feet to 350 feet
From 370 feet to 390 feet
From 413 feet to 478 feet
From feet to feet

9. WATER LEVEL
Static water level 48½ feet below land surface
Flow 0 G.P.M. 0 P.S.I.
Water temperature COLD F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PLASKETT IRRIGATION (Contractor)
Address BOX 10 EUREKA NEV. (Contractor)
Nevada contractor's license number 11882
Nevada contractor's drillers number
Nevada driller's license number 635 (Actual Driller)
Signed James E. Groth ~~Contractor~~ DRILLER
Date 7-6-92

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434