

OFFICE USE ONLY
 Log No. 3982A
 Permit No. _____
 Basin 76

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21420

1. OWNER David Squires ADDRESS AT WELL LOCATION Duffy Road Lot #11
 MAILING ADDRESS 1300 W. 2nd Street Fernley, NV 89408
Reno, NV 89503

2. LOCATION NE 1/4 NE 1/4 Sec 7 T 20 N/S R 25 E Lyon County _____
 PERMIT NO. 23-778-09 Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	11	11
Brown Sandy Clay		11	34	23
Fine Brown Sand		34	38	4
Brown Sandy Clay		38	51	13
Brown Coarse Sand	X	51	62	11
Boulders & Sand		62	74	12
Sandy Yellow Clay		74	78	4
Boulders & Sand	X	78	100	22

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 100
10 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	100

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8"
 From 96 feet to 99 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 29 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling Inc. Contractor
 Address P.O. BOX 1265 Contractor
Fallon, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas Parsons
 By Driller performing actual drilling on site or contractor
 Date Nov 10, 1992


Date started November 4, 19 92
 Date completed November 4, 19 92

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

'92 NOV 13 AM 3:51
 STATE ENGINEER'S OFFICE



1919

1919