WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39825
Permit No.
Basin 76

NOTICE OF INTENT NO. 15563

1. OWNER: Elsie Perry
MAILING ADDRESS: Rt 1 Box 360, Fernley, Nv 89408
ADDRESS AT WELL LOCATION: Rt 1 Box 360, Farm District Rd

2. LOCATION: SW ¼ NW ¼ Sec. 22 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) — Parcel No. 21-341-03 — Subdivision Name: Lyon County/ Fernley

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Brown clay		10	45	35
Brown clay coarse sand and gravels		45	50	5
Coarse sands & gravels		50	70	20
Coarse sands & gravels & brown clay		70	115	45
Brown clay		115	125	10
Brown clay coarse sands & gravel		125	149	24
T.D. 149 ft				

Date started 10/8/92, 19
Date completed 10/10/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		1

8. WELL CONSTRUCTION
Depth Drilled 149 Feet Depth Cased 139 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11	0	50
8 3/4	50	149

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	149

Perforations:
Type perforation: factory
Size perforation: 3/32 X 3
From 109 feet to 129 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal: 50
Placement Method: [XX] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 149 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Aqua Drilling & Well Service, Inc
Address (Contractor): 625 Spice Islands Dr Suite L, Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board: 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1132
Signed (By driller performing actual drilling on site or contractor)
Date: Roger M. Thrall 10/16/92

NOV 19 '92 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627