

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 39828
 Permit No. _____
 Basin 84

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20549

1. OWNER George Gosar ADDRESS AT WELL LOCATION Niel Gurr Construction
 MAILING ADDRESS 1930 Windsor Way 3040 Barranca
Reno, NV, 89523 Sparks, NV, 89436
 2. LOCATION SW 1/4 SW 1/4 Sec. 11 T. 21 N/S R. 21 E. Washoe County
 PERMIT NO. 76-300-42 Spanish Springs Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Clay With D.G.		1	4	3
Weathered Granite		4	16	12
Green Granite		16	54	38
Fracture (no water)		54	55	1
Green Granite		55	78	23
Gray Granite w/some clay streaks		78	146	68
Gray Granite		146	271	125
Soft Zone (no water)		271	272	1
Gray Granite		272	331	59
Soft Zone (no water)		331	332	1
Gray Granite		332	421	89
Soft Zone (no water)		421	422	1
Gray Granite		422	557	135
Soft Zone (no water)		557	558	1
Gray Granite		558	728	170
Soft Zone	X	728	735	7
Gray Granite		735	777	42
Fracture	X	777	779	2
Gray Granite		779	800	21

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 800 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 50 Feet
 To 8 5/8 Inches 50 Feet 800 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	800

Perforations: Factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From _____ feet to _____ feet
 From 713-733 feet to 753-793 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 800 feet

9. WATER LEVEL
 Static water level 710 feet below land surface
 Artesian flow 12 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

Date started October 26, 1992, 19____
 Date completed November 4, 1992, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV, 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number 923 issued by the Division of Water Resources, the on-site driller
 Signed Wayne Drilling Inc.
 By Wayne Drilling Inc. Driller performing actual drilling on site or contractor
 Date November 9, 1992